

Approval Number 240155020
Test Report: J-00471647



29th January 2024

Guarniflon SpA
Via T Tasso 12,
24060 Castelli Calepio (BG),
Italy

Water Regulations Approval Scheme Ltd.
Unit 13,
Willow Road,
Pen y Fan Industrial Estate,
Crumlin,
Gwent,
NP11 4EG

WATER REGULATIONS APPROVAL SCHEME LTD. (WRAS)
MATERIAL APPROVAL

The material referred to in this letter is suitable for contact with wholesome water for domestic purposes having met the requirements of BS6920-1:2000 and/or 2014 'Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water'.

The reference relates solely to its effect on the quality of the water with which it may come into contact and does not signify the approval of its mechanical or physical properties for any use.

POLYTETRAFLUOROETHYLENE (PTFE)- COMPONENTS.

5294

'PTFE G439'. Terracotta coloured, extruded PTFE sealing ring.
For use with water up to 85°C.

APPROVAL NUMBER: 240155020
APPROVAL HOLDER: GUARNIFLON SPA

The Scheme reserves the right to review approval.
Approval 240155020 is valid between January 2024 and January 2029

An entry, as above, will accordingly be included in the Water Fittings Directory on-line under the section headed, "Materials which have passed full tests of effect on water quality".

The Directory may be found at: www.wrasapprovals.co.uk/approvals-directory/

Yours Faithfully

A handwritten signature in blue ink, appearing to read 'Ian Hughes', is written over a horizontal line.

Ian Hughes
WRAS Approvals Manager