

Approval Number 240655042  
Test Report: J-00491299



26<sup>th</sup> June 2024

Guarniflon SpA  
Via T Tasso 12,  
24060 Castelli Calepio (BG),  
Italy

Water Regulations Approval Scheme Ltd.  
Unit 13,  
Willow Road,  
Pen y Fan Industrial Estate,  
Crumlin,  
Gwent,  
NP11 4EG

**WATER REGULATIONS APPROVAL SCHEME LTD. (WRAS)**  
**MATERIAL APPROVAL**

The material referred to in this letter is suitable for contact with wholesome water for domestic purposes having met the requirements of BS6920-1:2000 and/or 2014 'Suitability of non-metallic products for use in contact with water intended for human consumption with regard to their effect on the quality of the water'.

The reference relates solely to its effect on the quality of the water with which it may come into contact and does not signify the approval of its mechanical or physical properties for any use.

**POLYTETRAFLUOROETHYLENE (PTFE)- COMPONENTS.**

**5294**

'PTFE G300 Seat'. White coloured, extruded PTFE seat component. For use with water up to 85°C.

**APPROVAL NUMBER: 240655042**  
**APPROVAL HOLDER: GUARNIFLON SPA**

The Scheme reserves the right to review approval.  
Approval 240655042 is valid between June 2024 and June 2029

An entry, as above, will accordingly be included in the Water Fittings Directory on-line under the section headed, "Materials which have passed full tests of effect on water quality".

The Directory may be found at: [www.wrasapprovals.co.uk/approvals-directory/](http://www.wrasapprovals.co.uk/approvals-directory/)

Yours Faithfully

**Ian Hughes**  
**WRAS Approvals Manager**